

## TECHNICAL BULLETIN

**[Issue No.]** T30-0003

**[Page]** 1/1

**[Title]** Condition of Lloyd type approval system  
for QnA and Q4AR Series

**[Date of Issue]** Dec. '99

**[Relevant Models]** All models in QnA and Q4AR Series

---

Thank you for your continued patronage of the Mitsubishi general-purpose PLC QnA and Q4AR Series.

Lloyd Type Approval system certified MELSEC-QnA and Q4AR Series for use in use of environmental category ENV2 as specification No.1-1996. The following described the detail.

### Whereas

[Details]

- **Condition**

- (1) **Working ambient temperature**

The working ambient temperature specified in the Mitsubishi PLC general specifications differ from the working ambient temperature specified in the Environment Class ENV2 of the Lloyd Type Approval System as specified in Lloyd Register's test specification No.1-1996.

	<b>Mitsubishi PLC general specifications</b>	<b>Lloyd Type Approval System</b>
Working ambient temperature	0°C to +55°C	+5°C to +55°C

Use the models within the working ambient temperature range specified in the Lloyd Type Approval System.