

TECHNICAL BULLETIN

[Issue No.] FA-A-0070

[Page] 1/2

[Title] Production discontinuation of Q series power supply module

[Date of Issue] September 2009

[Relevant Models] Q64P

Thank you for your continued support of Mitsubishi programmable controllers, MELSEC-Q series.

Production of the following Q series power supply module, Q64P, will be discontinued.

1. Model to be discontinued

Product name	Model
Power supply module	Q64P

2. Schedule

- Transition to “made-to-order”: November 30, 2009
- Order deadline: December 25, 2009
- Production discontinuation: February 26, 2010

3. Reasons for discontinuing production

An alternative upgraded model, the Q64PN, has been released in December 2007, and has acquired the following certificates:

- DNV certificate
- Lloyd's certificate
- NK certificate
- BV certificate
- ABS certificate
- RINA certificate
- GL certificate

4. Repair acceptance

Repair acceptance: Through February 28, 2017 (for 7 years after production discontinuation)

TECHNICAL BULLETIN

[Issue No.] FA-A-0070

[Page] 2/2

[Title] Production discontinuation of Q series power supply module

[Date of Issue] September 2009

[Relevant Models] Q64P

5. Specifications comparisons with the alternative model

Item	Model	Discontinued model	Alternative model
		Q64P	Q64PN
Input power supply		100V to 120V AC or 200V to 240V AC	100V to 240V AC
Weight		0.40kg	0.47kg

* For other than the above, the alternative model has the same specifications as the discontinued model.

6. Replacement with the alternative model

(1) Wiring precautions

- The existing external power supply can be used as it is.
- The terminal layout of the alternative is the same as that of the discontinued model.

(2) Utilization of existing programs

- There is no need for any program modifications.