



CERTIFICATE NUMBER 22-2203953-PDA

EFFECTIVE DATE 18-JAN-2022

EXPIRATION DATE 17-JAN-2027

ABS TECHNICAL OFFICE Yokohama Engineering Services

CERTIFICATE OF

Product Design Assessment

This is to certify that a representative of this Bureau did, at the request of

MITSUBISHI ELECTRIC CORPORATION FUKUYAMA WORKS

located at

FUKUYAMA CITY, JAPAN

assess design plans and data for the below listed product. This assessment is a representation by the Bureau as to the degree of compliance the design exhibits with applicable sections of the Rules. This assessment does not waive unit certification or classification procedures required by ABS Rules for products to be installed in ABS classed vessels or facilities. This certificate, by itself, does not reflect that the product is Type Approved. The scope and limitations of this assessment are detailed on the pages attached to this certificate.

Product Molded Case Circuit Breaker


Model NF Series

This Product Design Assessment (PDA) Certificate remains valid until 17-January-2027 or until the Rules and/or Standards used in the assessment are revised or until there is a design modification warranting design reassessment (whichever occurs first).

Acceptance of product is limited to the "Intended Service" details prescribed in the certificate and as per applicable Rules and Standards.

This Certificate is valid for installation of the listed product on ABS units which exist or are under contract for construction on or previous to the effective date of the ABS Rules and standards applied at the time of PDA issuance. Use of the Product for non-ABS units is subject to agreement between the manufacturer and intended client.

American Bureau of Shipping


Motohiro Taruza
Engineer/Consultant

NOTE: This certificate evidences compliance with one or more of the Rules, Guides, standards or other criteria of ABS or a statutory, industrial or manufacturer's standards. It is issued solely for the use of ABS, its committees, its clients or other authorized entities. Any significant changes to the aforementioned product without approval from ABS will result in this certificate becoming null and void. This certificate is governed by ABS Rules 1-1-A3/5.9 Terms and Conditions of the Request for Product Type Approval and Agreement (2010)

MITSUBISHI ELECTRIC CORP.

FUKUYAMA WORKS, 1-8 MIDORI-MACHI

FUKUYAMA CITY HIROSHIMA PREF.

Japan 720-8647

Telephone: 81-84-926-8156

Fax: 81-84-931-4714

Email: Okagawa.Shinichi@aj.MitsubishiElectric.co.jp

Web: www.mitsubishielectric.co.jp

Tier: 2 - PDA Issued

Product: Molded Case Circuit Breaker

Model: NF Series

Endorsements:

Intended Service:

Protection against overload and short-circuit in electric circuits

Description:

Low Voltage Circuit Breakers, refer to attached list

Rating:

Detail ratings for each type, see component list attached to PDA Certificate.

Service Restriction:

(a) The Product Unit Certification is not required.

(b) If the manufacturer or purchaser request an ABS Certificate for compliance with a specification or standard, the specification or standard, including inspection standards and tolerances, must be clearly defined. Details of each particular application including wiring diagram, location/installation of sensors are to be specifically approved by ABS.

Comments:

(a) The Manufacturer has provided a declaration about the control of, or the lack of Asbestos in this product.

(b) Unless specially directed by Administration, this approval is not to be construed as a substitute for flag Administration's approval.

(c) Color for breaker cover: Black, Ivory.

Notes/Drawing/Documentation:

Drawing No. --, INFORMATION FOR APPLICATION, dated 11 December 2001

Drawing No. --, INFORMATION FOR APPLICATION, dated 28 July 2006

Drawing No. --, Construction Details Drawing, Rev: 0

Drawing No. --, TEST REPORT dated 31 July 2001 issued by MITSUBISHI ELECTRIC CORP.

Drawing No. --, TEST REPORT dated 31 July 2006 issued by MITSUBISHI ELECTRIC CORP.

Terms of Validity:

This Product Design Assessment (PDA) Certificate remains valid until 17/Jan/2027 or until the Rules and/or Standards used in the assessment are revised or until there is a design modification warranting design reassessment (whichever occurs first).

Acceptance of product is limited to the "Intended Service" details prescribed in the certificate and as per applicable Rules and Standards.

This Certificate is valid for installation of the listed product on ABS units which exist or are under contract for construction on or previous to the effective date of the ABS Rules and standards applied at the time of PDA issuance. Use of the Product for non-ABS units is subject to agreement between the manufacturer and intended client.

STANDARDS

ABS Rules:

2022 Marine Vessel Rules: 1-1-4/7.7, 1-1-A3, 1-1-A4, 4-8-2/9.3.7 and 4-8-3/5.3.3(a)

2022 High Speed Craft Rules: 1-1-4/11.9, 1-1-A2, 1-1-A3, 4-6-2/9.1.4(b) and 4-6-4/11.1.1

mitsubishi electric corp.

FUKUYAMA WORKS, 1-8 MIDORI-MACHI

FUKUYAMA CITY HIROSHIMA PREF.

Japan 720-8647

Telephone: 81-84-926-8156

Fax: 81-84-931-4714

Email: Okagawa.Shinichi@aj.MitsubishiElectric.co.jp

Web: www.mitsubishielectric.co.jp

Tier: 2 - PDA Issued

2022 Mobile Offshore Units Rules: 1-1-4/9.7, 1-1-A2, 1-1-A3 and 4-3-2/9.1.4(b)

National:

NA

International:

IEC 60947-2 Ed. 5.1 b:2019

Government:

NA

EUMED:

NA

OTHERS:

NA

Product Design Assessment (PDA) Certificate Attachment for Component Details

PDA Certificate No: 22-2203953-PDA
Entry Date: 18 January 2022
Expire Date: 17 January 2027
Company: Mitsubishi Electric Corporation
Factory or Works: Fukuyama Works
Product/Equipment: Molded Case Circuit Breaker
Model: NF Series

Type	Size (A)		AC				DC	
			Rated Current(A)	Volt. (V)	Breaking Current rms-sym Icu(*7)/Ics(*6) (kA)	Making Current peak-asym Icm (kA)	Volt. (V)	Breaking Current Icu(*7)/Ics(*6) (kA)
NF30-CS (*3)	30	AC:	3,5,10,15,20,30	440 240	1.5/1.5 2.5/2	2.16 3.46(*5)/2.78	-- --	-- --
NF400-CW(*3)	400	AC:	250,300,350,400	230 450 500	50/25 25/13 15/8	105(*6) 52.5(*5) 30(*5)	--	--
		DC:	250,300,350,400	--	--	--	250	20/10
NF400-CEW (*1) (*4)	400	AC:	200-400	200	50/25	105(*5)	--	--
				450	25/13	52.5(*5)		
				500	15/8	30(*5)		
NF400-SW (*3)	400	AC:	250,300, 350,400	230	85/85	187	--	--
				450	42/42	88.2		
				450	50/38	105(*5)		
				500	30/30	63		
				DC:	250,300,350,400	--	--	--
NF400-SEW (*1) (*4)	400	AC:	200-400	230	85/85	187	--	--
				450	42/42	88.2		
				450	50/38	105(*5)		
				500	30/30	63		
NF400-HEW (*1) (*4)	400	AC:	200-400	230	100/100	220	--	--
				450	65/65	143		
				500	50/50	105		
NF400-REW (*1) (*4)	400	AC:	200-400	230	150/75	330(*5)	--	--
				450	125/63	275(*5)		
				500	70/35	154(*5)		
NF400-U EW (*1) (*4)	400	AC:	200-400	230	200/200	440	--	--
				450	200/200	440		
				500	170/170	374		
NF630-CW (*3)	630	AC:	500,600,630	230	50/25	105(*5)	--	--
				450	36/18	75.6(*5)		
				500	18/9	36(*5)		
				DC:	500,600,630	--	--	--
NF630-CEW (*1) (*4)	630	AC:	300-630	230	50/25	105(*5)	--	--
				450	36/18	75.6(*5)		
				500	18/9	36(*5)		
NF630-SW (*3)	630	AC:	500,600,630	230	85/85	187	--	--
				450	42/42	88.2		
				450	50/38	105(*5)		
				500	30/30	63		
				DC:	500,600,630	--	--	--
NF630-SEW (*1) (*4)	630	AC:	300-630	230	85/85	187	--	--
				450	42/42	88.2		
				450	50/38	105(*5)		
				500	30/30	63		
NF630-HEW (*1) (*4)	630	AC:	300-630	230	100/100	220	--	--
				450	65(*5)/65	143		
				500	50(*5)/50	105		
NF630-REW (*1) (*4)	630	AC:	300-630	230	150/75	330(*5)	--	--
				450	125/63	275(*5)		
				500	70/35	154(*5)		
NF800-CEW (*1) (*4)	800	AC:	400-800	230	50/25	105(*5)	--	--
				450	36/18	75.6(*5)		
				500	18/9	36(*5)		

Product Design Assessment (PDA) Certificate Attachment for Component Details

PDA Certificate No: 22-2203953-PDA
Entry Date: 18 January 2022
Expire Date: 17 January 2027
Company: Mitsubishi Electric Corporation
Factory or Works: Fukuyama Works
Product/Equipment: Molded Case Circuit Breaker
Model: NF Series

				AC			DC	
Type	Size (A)		Rated Current(A)	Volt. (V)	Breaking Current rms-sym Icu(*7)/Ics(*6) (kA)	Making Current peak-asm Icm (kA)	Volt. (V)	Breaking Current Icu(*7)/Ics(*6) (kA)
NF800-SEW (*1) (*4)	800	AC:	400-800	230	85/85	187	--	--
				450	42/42	88.2		
				450	50/38	105(*5)		
				500	30/30	63		
NF800-HEW (*1) (*4)	800	AC:	400-800	230	100/100	220	--	--
				450	65/65	143		
				500	50/50	105		
NF800-REW (*1) (*4)	800	AC:	400-800	230	150/75	330(*5)	--	--
				450	125/63	275(*5)		
				500	70/35	154(*5)		
NF1000-SEW (*4)	1000	AC:	500-1000	230	125/63	275(*5)	--	--
				450	85/43	187(*5)		
				500	65/33	143(*5)		
NF1250-SEW (*4)	1250	AC:	600-1250	230	125/63	275(*5)	--	--
				450	85/43	187(*5)		
				500	65/33	143(*5)		
NF1200-UR (*4)	1200	AC:	600,700,800, 1000, 1200 (*2)	230	170/85	390	--	--
				450	125/65	276		

Remarks

- (*1) solid state adjustable (continuous)
- (*2) adjustable (semi-fixed)
- (*3) long-time delay trip& instantaneous trip
- (*4) long-time delay trip, short-time delay trip & instantaneous trip
- (*5) making capacity corresponding to Icu
- (*6) rated service short-circuit breaking current Ics (See IEC60947-2)
- (*7) rated ultimate short-circuit breaking current Icu (See IEC60947-2)